

GHGT-10

Technical and economic assessment of ammonia-based post-combustion CO₂ capture

Peter Versteeg^a, Edward S. Rubin^a

^a*Department of Engineering and Public Policy, Carnegie Mellon University, 5000 Forbes Ave. Pittsburgh, 15213, USA*

Elsevier use only: Received date here; revised date here; accepted date here

Abstract

The performance and cost of two ammonia-based post-combustion CO₂ capture systems operating at a new supercritical coal-fired power plant were modeled and compared to an amine-based CO₂ capture system operating at a similar plant. This assessment showed that for a fixed coal input, the plant derating of a CO₂ capture system operating with high ammonia concentrations (HighNH₃) was found to be 2 percentage points lower than a plant with the amine-based system. The plant derating of a CO₂ capture system operating with low ammonia concentrations (LowNH₃) was substantially higher. Preliminary estimates of the revenue requirement of the plants with HighNH₃ and LowNH₃ systems are \$U.S. 117/MWh and \$U.S. 148/MWh respectively, compared to \$U.S. 119/MWh for a plant with an amine-based system. The results from this performance assessment and preliminary cost analysis suggest that the LowNH₃ system will not be competitive and that the HighNH₃ system may have a slight energy and cost advantage over the amine system. Furthermore, a preliminary uncertainty analysis explores the critical factors that may affect the performance and cost estimates of these systems, including the potential for slow reaction kinetics to increase absorber costs, and these results are presented.

© 2010 Elsevier Ltd. All rights reserved

Keywords: Post-combustion; chilled-ammonia; carbon capture and sequestration

1. Introduction

Policy makers face central questions about costs and effectiveness in assessing CO₂ emission mitigation options [1]. One such option is post-combustion CO₂ capture, which targets CO₂ emissions released from the burning of fossil fuels. Amine scrubbing is the leading post-combustion CO₂ capture technology, and is well understood and ready for large scale use [2]. Post-combustion CO₂ capture based on ammonia is less understood but is attractive because ammonia is inexpensive, the CO₂ can be regenerated at high pressure, and the steam requirements for the regeneration process may be lower than for amine-based technologies. This study presents a performance assessment and preliminary cost analysis of a power plant integrated with ammonia-based CO₂ capture, and compares the results to a plant with an amine-based system. Using tools that have already been developed, this paper is intended to be a starting point for estimating costs for this process, and will help policy makers be more informed about the costs of CO₂ emission mitigation options.

For comparing performance and costs between post-combustion CO₂ capture with ammonia and amine technologies, this paper uses the plant derating of CO₂ capture on the power plant and the levelized revenue required as two key parameters, as calculated in equation 1 and equation 2. The plant derating for CO₂ capture is expressed as the percentage reduction in net plant output for a constant energy input and is occasionally reported as an “energy penalty”.

$$\text{Plant Derating (\%)} = \frac{\text{Plant Efficiency without Capture} - \text{Plant Efficiency with Capture}}{\text{Plant Efficiency without Capture}} \quad (1)$$

$$\text{Revenue Required (\$/MWh)} = \frac{\text{Total Plant Costs} * \text{Fixed Charge Factor} + \text{O\&M Costs}}{8760 * \text{Capacity Factor} * \text{MWh Produced}} \quad (2)$$

* Corresponding author. Tel.: +1-412-567-7785
E-mail address: plv@andrew.cmu.edu.

Plant derating estimates of amine and ammonia-based CO₂ capture systems from previous studies are shown in Table 1. Early plant derating estimates of ammonia-based CCS are lower because initial studies assumed that an ammonia-based capture system could be designed around the low energy reaction between ammonium carbonate ((NH₄)₂CO₃) and ammonium bicarbonate (NH₄HCO₃). More recent studies have higher plant derating estimates because the formation of other chemical species was also found to be important [3].

Table 1: Comparison of plant derating estimates for amine and ammonia-based CO₂ capture systems.

Study Type	Plant Derating	Authors, Publication, Affiliation & Year	Notes	Ref
Amine				
Performance and Cost Estimate	28%	Buchanan et al., EPRI 2000	Calculated from data	[4]
Performance and Cost Estimate	30%	Woods et al., NETL 2007	Calculated from data	[5]
Vendor Estimate	23%	Kishimoto et al., MHI 2009	Estimated from data	[6]
Expert Elicitation	25-28%	Chung et al., 2009	Power plant retrofit in 2030	[7]
Ammonia				
Performance and Cost Estimate	17%	Ciferno et al., NETL 2005	Calculated in study	[8]
Performance and Cost Estimate	10-14%	Gal, EPRI 2006	Calculated from data	[9]
Vendor Estimate	9%	Peltier, Powermag 2008	Calculated from data from Alstom	[10]
Performance Estimate	13%	Valenti et al. 2008	Calculated from data	[11]
Performance Estimate	28%	Mathias et al., Fluor 2008	Estimated from data	[3]
Vendor Estimate	17%	McLarnon et al., Powerspan 2009	Calculated from data	[12]
Vendor Estimate	20%	Hilton et al., Alstom 2009	Estimated by Alstom	[13]
Expert Elicitation	17-20%	Chung et al. 2009	Power Plant Retrofit in 2030	[7]

2. Methodology

The characteristics of the power plant used in this study are derived from the 2007 DOE/NETL Bituminous Baseline report (Case 12) [5]. This plant is a pulverized coal, supercritical Rankine cycle plant that burns Illinois No. 6 coal and is located in the Midwestern USA. The plant is fitted with a Fluor Econamine FG Plus process, and in this study the flue gas into this system is used as the feed for the ammonia-based systems.

To simulate CO₂ capture using ammonia, an equilibrium electrolyte model developed for this purpose by Aspen Technologies is used [14]. Aqueous ammonium bicarbonate (NH₄HCO₃), ammonium carbonate ((NH₄)₂CO₃), and ammonium carbamate (NH₂COONH₄) as well as the salt precipitate of ammonium carbonate can occur, depending on process conditions. Salt precipitation lowers the concentration of aqueous ammonium bicarbonate allowing additional CO₂ to be absorbed. Multiple ammonia-based CO₂ capture systems can be designed by taking advantage of different aspects of the chemistry.

The basic process steps and conditions for ammonia-based CCS are taken from a patent application by Gal [15], a presentation by Hilton et al. [13], and work by Mathias et al. [3], and the major features are modelled in Aspen Plus® (V7.1) as shown in Figure 1. Power plant flue gasses are initially cooled using circulating water and a direct contact cooler, and most of the water in the gases are condensed out. The flue gases are further cooled in a cross flow heat exchanger using chilled water from a vapour compressor. The chilled flue gasses feed into a CO₂ absorption column at 10°C and 1 atm, where the gases are contacted with a lean solvent mixture. The lean solvent contains ammonia, carbon dioxide, and water, and has a lean loading NH₃/CO₂ ratio of 2.85. As shown in Figure 2a, higher ratios result in increased ammonia slip over the absorber and therefore increased flue gas cleaning demands, while lower ratios require additional solvent flow or higher ammonia concentrations to capture 90% CO₂. The ratio of 2.85 was chosen as a compromise between these two issues. The CO₂ rich stream leaves the bottom of the absorber and is compressed to 3.0 MPa by a high pressure pump. The rich solution then flows through a cross flow heat exchanger where it is heated by the hot lean solution coming off the reboiler, and if any solids remain in the stream a heater is used to dissolve them. Steam is used in the CO₂ stripper to regenerate the CO₂ at 2.8 MPa, and the regenerated solvent is then returned to the absorber. The absorber gasses are cleaned of ammonia in a water wash and are then heated in a second direct contact cooler, before being released through the stack. Finally, distillate from the second stripper containing ammonia, carbon dioxide, and water is fed back to the CO₂ absorber. Several components were modelled separately in Excel®, including the CO₂ compressor equipment and the water chillers that supply cooling loads.




Figure 1: The ammonia-based CO₂ capture performance model.

The ammonia concentrations and solvent flow rates in the CO₂ capture process affect performance and equipment cost. The impact of varied ammonia concentrations over a consistent design is absent in the literature and so we present a sensitivity analysis of the effect of ammonia concentration and solvent flow rate on CO₂ absorption. The results for percent CO₂ capture in the absorber, absorber ammonia slip, and solids content out of the bottom of the absorber are shown in Figure 2b, 2c, and 2d respectively. Increases in CO₂ capture results in higher ammonia slip, while the use of low flow rates or high ammonia concentrations cause ammonia salts to precipitate in large quantities.

From the results of the sensitivity analysis two CO₂ capture system designs were considered, a low concentration ammonia system operating without solids (LowNH₃) and a high concentration system operating with a rich solvent absorber outlet stream of 60 wt% solids (HighNH₃). Additional lean solvent ammonia would result in salt precipitation for LowNH₃, while HighNH₃ has a rich solvent solids content equivalent to the highest solids wt % for ammonia-based CCS found in the literature [3]. The designs for both systems include flue gas cooling, absorber cooling, and ammonia cleanup of the flue gas. For both LowNH₃ and HighNH₃, the key design variables, process conditions, and predicted flows are shown in Table 2. The minimum temperature approach for the heat exchangers in both systems is 5.6°C, with the exception of Heat Exch. 3 for LowNH₃, which has a temperature approach of 20°C to control costs for this piece of equipment.




Figure 2: a) Lean loading vs. absorber CO₂ capture and absorber NH₃ slip, b) lean solvent NH₃ concentration vs. CO₂ capture, c) lean solvent NH₃ concentration vs. absorber NH₃ slip, and d) lean solvent NH₃ concentration vs. solids flow rate. Diamonds represent 90% CO₂ capture.

Table 2: Key process conditions and flows for the ammonia-based CO₂ capture system designs.

Parameter	LowNH ₃	HighNH ₃
Flue Gas Flow Rate into the System (kg/sec)	860	860
Flue Gas CO ₂ Mole Fraction	13.3	13.3
Flue Gas Circulating Water Flow Rate (kg/sec)	1452	1452
Flue Gas Water Wash Cleaning Water Flow Rate (kg/sec)	32	36
Flue Gas HeatX 2 Chilling Load (10 ³ tons cooling/ hr @ 3°C)	10	10
CO ₂ Absorber Solvent Flow Rate (kg/sec)	3,400	500
CO ₂ Absorber Lean Solvent NH ₃ Concentration (wt%)	6.75%	21.5%
CO ₂ Absorber Chilling Load (10 ³ tons cooling/ hr @ 3°C)	70	107
CO ₂ Absorber CO ₂ Removal Efficiency (%)	90%	90%
CO ₂ Absorber Ammonia Slip (ppm)	2112	2488
CO ₂ Absorber Rich Stream Solids Content (wt%)	No Solids Occur	60%
Lean Solvent Chilling Load (10 ³ tons cooling/ hr @ 3°C)	88	5
Overall Ammonia Slip (ppm)	<1	<1
Overall CO ₂ Capture (%)	90%	90%
Overall CO ₂ Product Purity (vol%)	99.8%	99.8%

3. Power Plant Performance

The power usage of both LowNH₃ and HighNH₃, including the electrical equivalent in steam drawn off after the intermediate turbine, is shown in Table 3 along with the resulting performance characteristics of the power plant. The performance estimates are based primarily on performance data from Aspen Plus® as well as data scaled from the Integrated Environmental Control Model (IECM V6.2), a program which can provide performance and cost estimates for power plants [16]. The plant derating of the HighNH₃ was found to be 2 percentage points lower than the plant derating of the amine-based system. The plant derating of LowNH₃ however, was found to be 9 points higher. This suggests that the LowNH₃ system will not be competitive. HighNH₃ performs relatively well due to the energy benefits associated with higher CO₂ loading and reduced heating, cooling, and transportation energy requirements.

Table 3: Power plant performance estimates. All values are in MWe equivalent

	No CO ₂ Capture [5]	Amine System [5]	LowNH ₃	HighNH ₃	Notes and Primary Data Sources for Calculation
Potential Power Available	580.2	827.6	827.6	827.6	Based on coal flow rate
Auxiliary Steam Load					
Heater				14.8	Aspen Plus
CO ₂ Stripper		164.2	163.0	87.0	Aspen Plus
NH ₃ Stripper			3.5	3.6	Aspen Plus
Steam Turbine Power	580.2	663.4	661.1	722.2	Based on aux. steam load
Auxiliary Electrical Load					
Flue Gas Blower			18.9	18.9	$\Delta P=3$ psi, scaled IECM data
Gas Cooling Water Pumps			3.2	3.2	Aspen Plus, scaled IECM data
Chiller for Heat Exch 2			5.7	5.7	Aspen Plus, [17], [18]
Chiller for Absorber Cooling			38.4	58.9	Aspen Plus, [17], [18]
Chiller for Solvent Cooling			48.5	3.0	Aspen Plus, [17], [18]
Absorber Cooling Pumps			3.5	5.4	Aspen Plus, scaled IECM data
Solvent Circulation Pumps			1.5	0.2	Aspen Plus, scaled IECM data
Econamine FG Plus System		23.2			
CO ₂ Compression		46.9	17.0	17.0	Aspen Plus, scaled IECM data, [5]
Balance of Plant	30.1	49.2	49.0	49.0	Scaled IECM data
Plant Net Power	550.1	546.0	475.2	560.8	
Plant Efficiency (% HHV)	39.1%	27.2%	23.7%	28.0%	
Plant Derating of CO ₂ Capture (%)		30.4%	39.4%	28.5%	Equation 1

4. Power Plant Costs

Preliminary cost results for the two ammonia-based CO₂ capture system designs in 2007 constant dollars are shown in Table 4. The cost estimates are based on data from the IECM, sources from the literature, and Aspen Icarus®. The costs for a number of components are scaled according to the methodology described in [19]. All the plants in Table 6 are assumed to have a levelized capacity factor of 75% over their lifetimes. The capital costs for both HighNH₃ and LowNH₃ are higher than for the amine system. Revenue required estimates for the plants with HighNH₃ and LowNH₃ systems are \$U.S.117/MWh and \$U.S.148/MWh respectively and compare to \$U.S.119/MWh for the plant with amine-based CO₂ capture. The plant with HighNH₃ has a higher efficiency, which leads to a slight cost advantage compared to the plant with amine-based CO₂ capture. In comparison with LowNH₃, HighNH₃ again benefits from smaller equipment sizes associated with higher loading and reduced heating, cooling, and transportation requirements.

The absorber in HighNH₃ is required to handle significant amounts of solids and was therefore considered a spray tower with capital costs similar to that of a wet flue gas desulfurization system. This cost estimate may be optimistic because modeling is based on equilibrium assumptions which may not apply in all cases. Given that a very large absorber would be required for a close approach to equilibrium, and that previous investigations on the kinetics of ammonia based CO₂ capture have shown that absorption may be slower than for monoethanolamine (MEA) based CO₂ capture [20], the absorber for this system may be significantly more expensive than the estimate provided here. This issue is considered further in the uncertainty analysis in Section 5.

Table 4: Power plant cost estimates with ammonia-based CO₂ capture, values are in 2007 \$Millions

	No CO ₂ Capture ¹	Amine System ¹	LowNH ₃	HighNH ₃	Notes and Primary Data Sources for Calculation
CO₂ Capture Process Area Costs					
DCC #1			30.9	30.9	Aspen Plus, scaled IECM data, [19]
DCC #2			23.3	23.3	Aspen Plus, scaled IECM data, [19]
Flue Gas Blower			6.4	6.4	Aspen Plus, scaled IECM data, [19]
Heat Exch. 1			6.7	6.7	Aspen Icarus
Heat Exch. 2			2.9	2.9	Aspen Icarus
Heat Exch. 1 Pumps			1.4	1.4	Aspen Plus, scaled IECM data, [19]
Heat Exch. 2 Pumps			0.5	0.5	Aspen Plus, scaled IECM data, [19]
Cooling Water Circ Pumps			0.7	0.7	Aspen Plus, scaled IECM data, [19]
Chiller System			74.3	54.3	Aspen Plus, [18]
Absorber			74.4	105.1	Aspen Plus, scaled IECM data
Absorber Pumps			1.9	2.5	Aspen Plus, scaled IECM data, [19]
Heat Exch. 3			74.7	19.2	Aspen Icarus
Solvent Circulation Pumps			16.5	5.2	Aspen Plus, scaled IECM data, [19]
Solvent Heater			0.0	2.5	Aspen Icarus
Solvent Cooler			37.5	2.3	Aspen Icarus
CO ₂ Stripper			66.5	21.0	Aspen Plus, scaled IECM data, [19]
CO ₂ Stripper Reboiler			33.2	7.2	Aspen Plus, scaled IECM data, [19]
Water Wash			2.2	2.2	Aspen Icarus
Heat Exch. 4			0.1	0.1	Aspen Icarus
NH ₃ Stripper			1.5	1.5	Aspen Icarus
NH ₃ Cleanup Pumps			1.0	1.1	Aspen Plus, scaled IECM data, [19]
Steam Extractor			3.3	3.3	Scaled IECM data
Sorbent Processing			1.1	1.1	Scaled IECM data
Drying and Compress Unit			18.3	18.3	Aspen Plus, scaled IECM data
General Facilities Capital			7.5	5.0	1.57 % PFC, [5]
Eng. & Home Office Fees			45.0	30.1	9.37 % PFC, [5]
Project Contingency Cost			78.5	52.6	16.38 % PFC, [5]
Process Contingency Cost			22.4	15.0	4.67 % PFC, [5]
CO ₂ System (TCR)		393.9	633.2	424.0	Based on Area Costs
Base Plant (TCR) ²	670.8	881.3	865.4	884.1	Scaled IECM data
Cooling Tower (TCR)	35.8	62.7	62.7	62.7	Scaled IECM data
NO _x Control (TCR)	25.0	33.7	33.7	33.7	Scaled IECM data
TSP Control (TCR)	37.4	49.8	49.8	49.8	Scaled IECM data
SO ₂ Control (TCR)	112.1	138.7	138.7	138.7	Scaled IECM data
CO ₂ System and TS&M O&M/Year		24.1	21.6	21.6	Scaled IECM data
Balance of Plant O&M/Year	103.1	128.9	128.9	128.9	Scaled IECM data
Plant Total Capital Requirement	881.1	1560.0	1783.5	1593.0	Based on TCR Costs
Total O&M Costs/Year	103.1	153.0	150.6	150.6	Total O&M
Capital Required (\$/kW-net)	1601.0	2857.0	3753.3	2840.5	Based on Performance
Revenue Required (\$/MWh)	60.4	118.7	148.2	116.5	Equation 2

¹The plants with amine-based CO₂ capture are based on Case 11 and Case 12 in [5], and were modelled in the IECM with a 75% capacity factor. ²The base plant cost is reduced for the low concentration ammonia-based CO₂ capture system design because a smaller steam turbine is required.

5. Uncertainty Analysis on Key CO₂ Capture System Performance Parameters

The performance and cost estimates have large uncertainties due to the limited availability of pilot plant data for model validation, the proprietary nature of industrial process designs now under development, and the limited commercial experience with building and operating commercial power plants with CCS. A preliminary uncertainty analysis using Monte Carlo simulation was used to illustrate the effect of uncertainty of key CO₂ capture system variables on the overall performance of the power plant. The uncertainty in each of the system variables was estimated from literature data where available, and probability distributions were assigned to the variables based on these

estimates, as shown in Table 5. The probability distribution for the CO₂ absorber costs is weighted to reflect that slower rates of reaction may negatively affect these costs. The stochastic results are shown in Figure 6.

Table 5: Key uncertainties associated with the CO₂ capture systems.

Parameter	Units	Nominal	Distribution Function
Solvent Chilling Loads		Table 3	Uniform(-25%,+25%)
Auxiliary Steam Loads		Table 3	Uniform(-25%,+25%)
ΔP Across Capture System	psi	3	Uniform(2, 4)
Chiller Electrical Use, 3°C Water Product	kW/ton	0.55	Triangular(0.50, 0.55, 0.60)
CO ₂ Compression, from 27.5 bar to 152.7 bar	kWh/kg CO ₂	0.03	Triangular(0.028, 0.03, 0.032)
Cooling Equipment Costs	\$/ton cooling	441	Uniform(-30%, +30%)
IECM Based Equipment Costs	\$	Table 4	Uniform(-30%, +30%)
Aspen Icarus® Based Equipment Costs	\$	Table 4	Uniform(-40%, +40%)
CO ₂ Absorber Costs	\$	Table 4	Uniform(-30%, +250%)
Power Plant Fixed Charge Factor	--	0.175	Uniform(0.16,0.19)
Power Plant Levelized Capacity Factor	--	0.75	Weibull(8.5, 0.81)




Figure 6: Cumulative probability distribution of plant performance (as reflected by the plant derating on the left) and total plant costs (levelized revenue requirement, on the right) of HighNH₃ and LowNH₃. The deterministic results are shown as a vertical line.

6. Discussion and Conclusion

The plant derating and equipment costs for low temperature CO₂ absorption are substantial for both LowNH₃ and HighNH₃. The cost estimates are higher for LowNH₃ due to larger equipment sizes, the energy requirements associated with high flowrates, and the extensive cooling loads required. The HighNH₃ system may have a slight energy and cost advantage over amine systems. A preliminary uncertainty analysis explored the critical factors that may affect the performance and cost estimates of these systems, and these results are presented.

The intent of this study was to provide reasonable preliminary performance and cost estimates of ammonia-based CO₂ capture system designs and relative comparisons with amine-based CO₂ capture systems. In the future the ammonia-based CO₂ capture performance and cost models could benefit from improved thermodynamic models, more detailed simulations of individual pieces of equipment including in particular the absorber, rate-based as opposed to equilibrium modelling, and cost estimates by vendors.

7. Acknowledgements

This work was supported by the U.S. Department of Energy's National Energy's Technology Laboratory (DOE/NETL), as well as the Natural Sciences and Engineering Research Council of Canada (NSERC). The authors would like to thank Gary Rochelle and Howard Herzog for their helpful comments on an early draft of this paper. All findings, conclusions, opinions or recommendations expressed in this paper are those of the authors alone and do not reflect the views of DOE, NSERC, or any other governmental agency.

8. References

- [1] Schaeffer M., Kram T., Meinshausen M., van Vuuren D.P., Hare W.L., “Near-linear cost increase to reduce climate change risk,” Proceedings of the National Academy of Sciences, Vol. 105, No. 52, pp 20621–20626, 2008
- [2] Rochelle G., “Amine Scrubbing for CO₂ Capture,” Science, Vol. 325, No.25, pp 1652-1654, 2009
- [3] Mathias P.M., Reddy S., Connell J. P., “Quantitative Evaluation of the Aqueous-Ammonia Process for CO₂ Capture Using Fundamental Data and Thermodynamic Analysis”, Energy Procedia, Vol. 1, No. 1, pp 1227-1234, 2009
- [4] Buchanan T., DeLallo M., Schoff R., White J., “Evaluation of Innovative Fossil Fuel Power Plants with CO₂ Removal” EPRI, Report No. 1000316, 2000
- [5] Woods M.C., Capicotto P., Haslbeck J., Kuehn N., Matuszewski M., Pinkerton L. L., Rutkowski M.D., Schoff R. L., Vaysman V., “Cost and Performance Baseline for Fossil Energy Plants, Volume 1: Bituminous Coal and Natural Gas to Electricity Final Report”, National Energy Technology Laboratory, 2007
- [6] Kishimoto S., Hirata T., Iijima M., Oshishi T., Higaki K., Mitchell R., “Current Status of MHI’s CO₂ Recovery Technology and Optimization of CO₂ Recovery Plant with a PC Fired Power Plant”, Energy Procedia, Vol. 1, pp 1091-1098, 2009
- [7] Chung T., Patino-Echeverri D., “Expert Assessments of CO₂ Capture Technologies, Retrofitting Existing Coal-fired Power Plants”, 8th Annual Conference on Carbon Capture & Sequestration, May 5, 2009
- [8] Ciferro J.P., DiPietro P., Tarka T., “An Economic Scoping Study for CO₂ Capture Using Aqueous Ammonia”, National Energy Technology Laboratory, 2005
- [9] Gal E., “Chilled-Ammonia Post Combustion CO₂ Capture System - Laboratory and Economic Evaluation Results”, EPRI, Report No. 1012797, 2006
- [10] Peltier R., “Alstom’s chilled ammonia CO₂-capture process advances toward commercialization”, Power, http://www.powermag.com/environmental/Alstoms-chilled-ammonia-CO2-capture-process-advances-toward-commercialization_86.html, February 15, 2008, Accessed December 1 2009
- [11] Valenti G., Bonalumi D., Macci E., “Energy and exergy analyses for the carbon capture with the Chilled Ammonia Process”, Energy Procedia, Vol. 1, No. 1, pp 1059-1066, 2009
- [12] McLarnon C.R., Jones M.D., “Testing of Ammonia Based CO₂ Capture with Multi-Pollutant Control Technology,” Proceedings of the 9th International Conference on Greenhouse Gas Control Technologies, in press, 2008
- [13] Hilton R. G., “Mountaineer CCS Project Begins Operations” Alstom Webinar presentation, September 11, 2009
- [14] AspenTech, “Rate-Based Model of the CO₂ Capture Process by NH₃ Using Aspen Plus” Solution ID 123405, February 11, 2008.
- [15] Gal E., “Ultra Cleaning of Combustion Gas Including Removal of CO₂” U.S. Patent Application No. US 2008/0072762 A1, Publication Date March 27, 2008.
- [16] Integrated Environmental Control Model (IECM), Carnegie Mellon University, <http://www.iecm-online.com/> Accessed December 1, 2009
- [17] Resource Dynamics Corporation (RDC) “Cooling, Heating, and Power for Industry: A Market Assessment”, 2003
- [18] Platts, “HVAC: Centrifugal Chillers”, 2004
- [19] Rao A.B. “Details of a Technical, Economic, and Environmental Assessment of Amine-based CO₂ Capture Technology for Power Plant Greenhouse Gas Control” IECM Documentation, 2002
- [20] Qin F., Wang S., Hartono A., Svendsen H.F., Chen C. “Kinetics of CO₂ absorption in aqueous ammonia solution”, International Journal of Greenhouse Gas Control, Vol. 4, pp 729-738, 2010